

REQ.NO : .96-13-4460

QTY	UNIT	DESCRIPTION	
6	NOS	PLENTY MIXERS COMPLETE WITH ELECTRIC MOTOR DUPLICATE TO THE FOLOWING TYPES AS BELOW PLENTY MIXER NEW BURY. RG. 145 TR S / N 6617602 / 2 MODEL / 31P -85A- S SM45 WHICH IS DUPLICATE TO MODEL 31P - 85 - S SM 45 ITEM NUMBER : MXR – MAX 80 °C SPEC. TAG. NUMBER : MTR – MAX : 54 °C ELECTRIC MOTOR TYPE :- M3JP225 SMD4 ABB POWER :- 45 KW DIRECT ON LINE SPEED :- 1433 R.P.M RATING VOLTAGE : 380 V , 50 HZ PHASE : 3 PH , AMP :- 86 P.F :- 0.8 INSULATION CLASS :- F AMB. :-55 °C ENCLOSURE EeX – DIIBT4 / IP55 FRAM MOUNTING :- 225 M / V1 WITH ELECTIC D.O.L.(EeXD IIBT4/IP55) STARTER COMPLETE SUITABLE TO START 45 KW MOTOR CONSIST OF 1- AIR CIRCUIT BREAKER 150 AMPER 3 PHASE 2- CONTACTOR 125 AMPER 3 PHASE 3- OVER LOAD 80-110 AMPER 4- VOLTMETER + AMMETER + (C.T) FOR THE AMMETER 5- SIGNAL LIGHTS RED - GREEN - YELLOW 6- ON PUSH BOTTOM . OFF PUSH BOTTOM 7- THREE POSTION SWITCH , FOR (LOCAL - REMOT - OFF) THE STARTER MUST BE COMPLETE AND READY TO START THE 45 KW MOTOR AND HAVE ALL THE NECESSARY PROTECTION MOUNTING FLANGE STANDARD : STANDARD 24" API 650 MANWAY O/D = 32.75" N.B = 24" NO.OF HOLES = 28 HOLE DIA = 0.875"	1
1	SET	RECOMMENDED SPARE PARTS FOR TWO YEARS A COMPLETE LIST ITEMIZED & PRICED FOR THE SPARES MUST ATTACHED WITH THE OFFEER .	2
3	SET	MANTINANCE , PART LIST , OPERATION MANUAL AND ALL ELECTRIC, MECHANIC DRAWING & WIRING DIAGRAM NOTES : WITNESS 4 S.O.C ENGINEERS SHOULD WITNESS THE FAT NSPECTION.ONE THE SUPPLIER ACCOUNT (FOR ALL COST) MUST BE INCLUDED . TRAINING 4 S.O.C PERSONS ON THE MANUFACTURER FACLITIEST ON THE SUPPLIER ACCOUNT (FOR ALL COUST) MUST BE INCLUDED . COUNTRY OF ORIGIN	3

| U.S.A , UK – WEST EUROPE , JAPAN . |