

A. TECHNICAL SPECIFICATIONS OF Diesel Fuel			
ITEM NO	ITEM DESCRIPTIONS	QUANTITY	UNIT
1	Diesel Fuel, density @15C(0.825-0.840). flash point C (60-75), sulphur <1000 to be used for operation of waste water treatment plant, water supply treatment plant, generators & machines.	45000	liters
B. Remarks and Conditions			
1	Delivery location: Duhok, Domiz camp 1, BRHA gas station.		
2	Consideration of safety and security measures during filling, trucking and discharging to tanks.		