

Tender Questions & Answers

FROM:	DANISH REFUGEE COUNCIL
Tender No:	ITB-IQ-TIK-2021-003
Tender Title:	Compact Units Rehabilitation
Tender Issuing Date:	01-07-2021
Tender Closing Date:	15-07-2021

Danish Refugee Council Iraq _____ has in reference to above tender period received the following questions

to the Tender, and hereby provides responsive answers by best endeavour to all relevant Vendors & Suppliers.

#	Enquiries to the Tender		
	Date	Question	Answer
1	11.02.2020	what is the duration of the contract implementation Period?	30 Calendar Days.
2	11.02.2020	Due to the fact that we'll be doing rehabilitation works in a WTP, we'll sometimes need to turn off the WTP and thus interruption to water supply will occur. how would we deal with situation knowing that it may lead to delays in implementation?	Salah Al-Din Directorate of Water as well as DRC are quite familiar with this issue and it is a highly anticipated scenario. thus, high level coordination levels is to be kept to minimize the shut downs of the WTP whenever possible. Salah Al-Din Directorate of Water will help mitigate this issue through Pipe Bypassing as well as community Mobilization and engagement whenever possible. DRC S&I Staff will work around the Hour to ensure proper coordination as well minimizing the shut down hours as much as possible.
3	04.02.2020	what happens if the Electrical Transformers accepted by DRC in the technical Bid are refused by respective Water directorate?	The BoQs were previously approved by Salah Al-Din Directorate of water. as long as the transformer technical specs meet standard specifications that are mentioned in the Paragraph in the Bid BoQ then it will be accepted. As such, all transformers meeting the specifications and pass the Quality tests in Salah Al-Din Directorate of Electricity Labs will be accepted.

On behalf of DRC

Yours sincerely,

12-07-2021